# **Daily Pool and Spa Log**

This is a legal document. It must be kept available for at least one year. Inspect half an hour before opening and every 2 hours (no automatic sensing device) or every 4 hours (automatic sensing device).

Date:	Name of facility:

## Half an hour before opening

Initial of operator	Time	Ground fault circuit interceptor (GFCI) activated	Emergency telephone test
		☐ Yes ☐ No	☐ Yes ☐ No

### **Hourly inspection log**

Initial of operator	Time	Free available chlorine Pools 0.5 to 10mg/L Stabilized pools 1 to 10mg/L Spas 5 to 10mg/L	Total chlorine Maximum 10mg/L	Bromine Pools 2 to 4mg/L Spas 5 to 10mg/L	<b>pH</b> 7.2 to 7.8	Total alkalinity 80 to 120mg/L	Oxidation reduction potential (ORP) 600 to 900mV	Water clarity Is the black disc visible from 9 metres away?	Spa water temperature Less than 40°C
								☐ Yes ☐ No	
								☐ Yes ☐ No	
								□ Yes □ No	
								☐ Yes ☐ No	
								□ Yes □ No	
								☐ Yes ☐ No	
								□ Yes □ No	
								□ Yes □ No	
								☐ Yes ☐ No	
								☐ Yes ☐ No	
								☐ Yes ☐ No	
								□ Yes □ No	

## **End of day**

Initial of operator	Time	Number of bathers	Water meter reading or spa drained, inspected and refilled Less than 4000L

#### Chemicals and breakdowns

Type and amount of chemicals added manually	Breakdowns or emergencies

